

271543

Faceplates and Connectors for Telecommunications Systems

Part 1 - General

Related Documents

The following related sections of the OT standards shall also be applicable to this section.

OT Engineer shall approve all product cut sheets prior to purchasing and installation by contractor. Reference S9 Approved Products.

S1 Approved Product Request

S1 Change Request

S1 Request for Variance

S1 Resource Allocation Permit

S2 Introduction

S3 SOP and Policy

S4 275116-TC CORE Passenger Communications Paging System

S4 275118-TC Emergency Communications and Evacuation Paging System

S5 270000X Telecommunications Systems (Boiler Plate)

S7 270000-TC Common Work

S7 270100-TC Systems Cabling

S7 270526-TC Grounding and Bonding

S7 270528-TC Hangers and Support

S7 270553-TC Identification

S7 270555-TC OT Facility Warning Standard

S7 271116-TC Cabinets Racks Frame Enclosures

S7 271119-TC Termination Blocks and Patch Panels

S7 271313-TC Cable Splicing and Termination

S7 271323-TC Optical Fiber Splicing and Terminations

S7 271519-TC Horizontal Cabling

S7 271525- TC Tenant and Airlines Extended DEMARC

S7 271600-TC Telecommunications Station Equipment

S8 E911 PS ALI Standard

S9 Approved Products

1.1 Work Included

- A. Provide all labor, materials, tools and equipment required for the complete installation of work called for in the Construction Documents

1.2 Scope of Work

- A. This document describes the products and execution requirements relating to furnishing and installing faceplates and connectors. Communications faceplates and connectors are covered under this document.
- B. The Communication Equipment Room shall support a minimum of (4) 4-pair Unshielded Twisted Pair (UTP) Copper Cables to each work area outlet unless otherwise noted for specific locations. The cables shall be installed from the Work Area Outlet to the Telecommunications Room (TR) located on the same floor, and routed to the appropriate rack serving that area and terminated as specified in this document.
- C. This section includes minimum requirements for the following:
 - Faceplates
 - Copper patch cords and modular connectors
 - Fiber optic patch cords and modular connectors
- D. All cables and related terminations, support and grounding hardware shall be furnished, installed, wired, tested, labeled, and documented by the telecommunications contractor as detailed in this document.
- E. Product specifications, general design considerations, and installation guidelines are provided in this document. Quantities of telecommunications outlets, typical installation details, cable routing and outlet types will be provided as an attachment to this document.

1.3 Regulatory References

- A. The following industry standards are the basis for the structured cabling system described in this document.
1. **TIA/EIA**
 - TIA/EIA-568-B Commercial Building Telecommunications Cabling Standard
 - TIA/EIA-569-A Commercial Building Standard for Telecom Pathways
 - TIA/EIA-606 Administration Standard for the Telecommunications Infrastructure of Commercial Buildings
 - TIA/EIA-607 Commercial Building Grounding/Bonding Requirements
 2. **NFPA**
 - NFPA-70 National Electric Code (NEC)-1999
 3. **ISO/IEC**
 - ISO/IEC 11801 Generic Cabling for Customer Premises
- B. The most recent versions of all documents shall apply to this project. If there is a conflict between applicable documents, the order above shall dictate the order of precedence in resolving the issue unless an enforceable local or national code is in effect.

Part 2 - Products

2.1 Equivalent Products

All outlets shall utilize fully the interchangeable and individual connector modules that mount side by side to facilitate quick and easy moves, adds and changes. All outlets and surface mount boxes shall be available in four colors including Off White.

2.2 Faceplates

Faceplates shall be one, two, and four single gang faceplates with combination head screws, screw covers, labels, label covers. The faceplates shall mount to standard U.S. NEMA boxes and adapters with screw-to-screw dimensions of 3.28" (83.3mm).

S7 271543-TC Faceplates and Connectors-3

2.3 Patch Cords and Modular Connectors - Copper

Patch cables are to be provided by contractor, color specified by OT.

2.4 Patch Cords and Modular Connectors – Fiber Optic

Patch cables are to be provided by contractor, color specified by OT.

Part 3 - Execution

3.1 Faceplate Configurations

- A. Faceplates shall be a four position unless a requirement for more than four positions is needed. Color of faceplate shall be match color specified by MAA/OT for specific location.
- B. Wall phone Faceplate. Provide a wall mounted shall be flush modular faceplate to house a single work area jack. The faceplate shall fit over a standard NEMA dual gang electrical outlet box fitted with a single gang plaster ring cover and shall be stainless steel. The faceplate shall be capable of having a wall-mounted telephone fitted directly over it.
- C. Furniture Faceplate. Shall be a flush mounted modular faceplate to house work area jacks, capable of housing a minimum of two jacks. The faceplate shall fit into a modular furniture raceway.
 1. Provide (4) Category 6. Two (2) blue jacket for Data, and two (2) white for Voice distribution cables running from each outlet back to the specified patch panel in the Communications Room (Distribution Frame) using the cable tray and conduit infrastructure.
 2. Terminate each Category 6 (Cat-6) distribution cable at each end on specified jack, terminations shall be the 568B wiring scheme.
 3. Face plates, jacks, labels and icons. Primary voice jack shall be Gray secondary jack shall be Black, faceplate shall be White. Primary data jack shall be Red secondary jack shall be Yellow faceplate should be Fog White

3.2 Horizontal Distribution Cable Installation

Cable shall be installed in accordance with manufacturer's recommendations and best industry practices.

A pull cord (nylon; 1/8" minimum) shall be co-installed with all cable installed in any conduit.

S7 271543-TC Faceplates and Connectors-4

Cable raceways shall not be filled greater than the TIA/EIA-569-A maximum fill for the particular raceway type or 40% whichever is greater.

Cables shall be installed in continuous lengths from origin to destination (no splices) except for transition points, or consolidation points.

Where transition points or consolidation points are allowed, they shall be located in accessible locations and housed in an enclosure intended and suitable for the purpose.

The cable's minimum bend radius and maximum pulling tension shall not be exceeded.

If a J-hook or trapeze system is used (with variance) to support cable bundles all horizontal cables shall be supported at a maximum of 48 to 60 inch (1.2 to 1.5 meter) intervals. At no point shall cable(s) rest on acoustic ceiling grids or panels.

Horizontal distribution cables shall be bundled in groups of no more than 48 cables. Cable bundle quantities in excess of 48 cables may cause deformation of the bottom cables within the bundle and degrade cable performance.

Cable shall be installed above fire-sprinkler systems and shall not be attached to the system or any ancillary equipment or hardware. The cable system and support hardware shall be installed so that it does not obscure any valves, fire alarm conduit, boxes, or other control devices.

Cables shall not be attached to ceiling grid or lighting fixture wires. Where support for horizontal cable is required, the contractor shall install appropriate carriers to support the cabling.

Any cable damaged or exceeding recommended installation parameters during installation shall be replaced by the contractor prior to final acceptance at no cost to the Owner.

Cables shall be identified by a self-adhesive label in accordance with the System Documentation Section of this specification and ANSI/TIA/EIA-606. The cable label shall be applied to the cable behind the faceplate on a section of cable that can be accessed by removing the cover plate.

Unshielded twisted pair cable shall be installed so that there are no bends smaller than four times the cable outside diameter at any point in the run and at the termination field.

Pulling tension on 4-pair UTP cables shall not exceed 25-lbf for a four-pair UTP cable.

3.3 Horizontal Cross Connect Installation

Cables shall be dressed and terminated in accordance with the recommendations made in the TIA/EIA-568-B standard, manufacturer's recommendations and best industry practices and in a professional manner.

Pair untwist at the termination shall not exceed 3.18 mm (0.5 inch).

Bend radius of the cable in the termination area shall not exceed 4 times the outside diameter of the cable.

Cables shall be neatly bundled and dressed to their respective panels or blocks. Each panel or block shall be fed by an individual bundle separated and dressed back to the point of cable entrance into the rack or frame.

The cable jacket shall be maintained as close as possible to the termination point.

Use of approved 24AWG, solid conductor cross connect shall be used. All cross connects shall be "Up, over and down" pattern. A slack loop of no less than .5 inch and no more than 1.0 inch shall be allowed

Each cable shall be clearly labeled on the cable jacket behind the patch panel at a location that can be viewed without removing the bundle support ties. Cables labeled within the bundle, where the label is obscured from view shall not be acceptable.

3.4 Optical Fiber Termination Hardware

Fiber slack shall be neatly coiled within the fiber splice tray or enclosure. No slack loops shall be allowed external to the fiber panel.

Each cable shall be individually attached to the respective fiber enclosure by mechanical means. The cables strength member shall be securely attached the cable strain relief bracket in the enclosure.

Each fiber bundle shall be stripped upon entering the splice tray and the individual fibers routed in the splice tray.

Each cable shall be clearly labeled at the entrance to the splice enclosure. Cables labeled as the bundle shall not be acceptable.

A maximum of 12 strands of fiber shall be spliced in each tray

All spare strands shall be installed into spare splice trays.

3.5 Copper Termination Hardware

Cables shall be dressed and terminated in accordance with the recommendations made in the ANSI/TIA/EIA-568-B standard, manufacturer's recommendations and best industry practice.

Pair untwist at the termination shall not exceed 3.18mm (0.5 inch).

Bend radius of the cable in the termination area shall not exceed 4 times the outside diameter of the cable.

Cables shall be neatly bundled and dressed to their respective panels or blocks. Each panel or block shall be fed by an individual bundle separated and dressed back to the point of cable entrance into the rack or frame.

The cable jacket shall be maintained to within 25 mm (one inch) of the termination point.

Each cable shall be clearly labeled on the cable jacket behind the patch panel at a location that can be viewed without removing the bundle support ties. Cables labeled within the bundle, where the label is obscured from view shall not be acceptable.

3.6 Identification and Labeling

- A. The contractor shall develop and submit for approval by OT a labeling system for the cable installation. The Owner will negotiate an appropriate labeling scheme with the successful contractor. At a minimum, the labeling system shall clearly identify all components of the system: racks, cables, panels and outlets. The labeling system shall designate the cables origin and destination and a unique identifier for the cable within the system. Racks and patch panels shall be labeled to identify the location within the cable system infrastructure. All labeling information shall be recorded on the as-built drawings

and all test documents shall reflect the appropriate labeling scheme.

- B. All label printing will be machine generated. Self-laminating labels will be used on cable jackets, appropriately sized to the OD of the cable, and placed within view at the termination point on each end. Outlet, patch panel and wiring block labels shall be installed on, or in, the space provided on the device.

3.7 Testing and Acceptance

A. General

1. All cables and termination hardware shall be 100% tested for defects in installation and to verify cabling system performance under installed conditions according to the requirements of ANSI/TIA/EIA-568-B, TSB-67 and TSB-155. All pairs of each installed cable shall be verified prior to system acceptance. Any defect in the cabling system installation including but not limited to cable, connectors, feed through couplers, patch panels, and connector blocks shall be repaired or replaced in order to ensure 100% useable conductors in all cables installed.
2. All cables shall be tested in accordance with this document, the ANSI/TIA/EIA standards. If any of these are in conflict, the Contractor shall bring any discrepancies to the attention of the project team for clarification and resolution.

B. Copper Channel Testing

All twisted-pair copper cable links shall be tested for continuity, pair reversals, shorts, opens and performance as indicated below. Additional testing is required to verify Category performance. Horizontal cabling shall be tested using a level IV test unit for category 6 or category 6 performance compliance, respectively.

Continuity - Each pair of each installed cable shall be tested using a test unit that shows opens, shorts, polarity and pair-reversals, crossed pairs and split pairs. Shielded/screened cables shall be tested with a device that verifies shield continuity in addition to the above stated tests. The test shall be recorded as pass/fail as indicated by the test unit in accordance with the manufacturers' recommended procedures, and referenced to the appropriate cable identification number and circuit or pair number. Any faults in the wiring shall be corrected and the cable re-tested prior to final acceptance.

S7 271543-TC Faceplates and Connectors-8

Length - Each installed cable link shall be tested for installed length using a TDR type device. The cables shall be tested from patch panel to patch panel, block to block, patch panel to outlet or block to outlet as appropriate. The cable length shall conform to the maximum distances set forth in the ANSI/TIA/EIA-568-A Standard. Cable lengths shall be recorded, referencing the cable identification number and circuit or pair number. For multi-pair cables, the shortest pair length shall be recorded as the length for the cable.

The four basic tests required in TSB-67 are:

- Wire Map
- Length
- Attenuation
- NEXT (Near end crosstalk)

Four additional tests are required per TSB-155:

- Return Loss
- ELFEXT Loss
- Propagation Delay
- Delay skew

In Amendment 5, two additional tests are required:

- PSNEXT (Power sum near-end crosstalk loss)
- PSELFEXT (Power sum equal level far-end crosstalk loss)

Where links are combined to complete a circuit between devices, the Contractor shall test each link from end to end to ensure the performance of the system. **ONLY BASIC LINK TEST IS REQUIRED.** The contractor can optionally install patch cords to complete the circuit and then test the entire channel. The test method shall be the same used for the test described above. The values for calculating loss shall be those defined in the ANSI/TIA/EIA Standard.

c. Fiber Testing

1. All fiber testing shall be performed on all fibers in the completed end-to-end system. There shall be no splices unless clearly defined in an RFP. Testing shall consist of an end-to-end power meter test performed per TIA/EIA-455-53A. The system loss measurements shall be provided at 850 and/or 1300 nanometers for multimode fibers and 1310 and/or 1550 nanometers for single mode fibers. These tests also include continuity checking of each fiber.

For horizontal cabling system using multimode optical fiber, attenuation shall be measured in one direction at either 850 nanometer (nm) or 1300 nm using an LED light source and power meter.

Backbone multimode fiber cabling shall be tested at both 850 nm and 1300 nm (or 1310 and 1550 nm for single mode) in one direction. The test shall be performed using a launch cable at the near and far end of test.

Test set-up and performance shall be conducted in accordance with ANSI/TIA/EIA-526-14 Standard, Method B.

Attenuation testing shall be performed with a stable launch condition using two-meter jumpers to attach the test equipment to the cable plant. The light source shall be left in place after calibration and the power meter moved to the far end to take measurements.

3.8 System Documentation

- A. Upon completion of the installation, the telecommunications contractor shall provide documentation sets to the MAA/OT for approval. Documentation shall include the items detailed in the sub-sections below.
- B. Documentation shall be submitted within ten (10) working days of the completion of each testing phase. This is inclusive of all test results and draft as-built drawings. Draft drawings may include annotations done by hand. Machine generated (final) copies of all drawings shall be submitted within 30 working days of the completion of each testing phase. At the request of the OT Engineer, the telecommunications contractor shall provide copies of the original test results.
- C. MAA/OT may perform a 10% random field re-test be conducted on the cable system, at no additional cost to the owner, to verify documented findings. Tests shall be a repeat of those defined above. If findings contradict the documentation submitted by the telecommunications contractor, additional testing shall be required to the extent determined necessary by the OT Engineer, including a 100% re-test. This re-test shall be at no additional cost to the Owner.

- D. **Test Results** documentation shall be provided on disk (electronic media) within three weeks after the completion of the project. The disk shall be clearly marked on the outside front cover with the words "Project Test Documentation", the project name, and the date of completion (month and year). The results shall include a record of test frequencies, cable type, conductor pair and cable (or outlet) I.D., measurement direction, reference setup, and crew member name(s). The test equipment name, manufacturer, model number, serial number, software version and last calibration date will also be provided at the end of the document. Unless the manufacturer specifies a more frequent calibration cycle, an annual calibration cycle is anticipated on all test equipment used for this installation. The test document shall detail the test method used and the specific settings of the equipment during the test as well as the software version being used in the field test equipment.
- E. The field test equipment shall meet the requirements of ANSI/TIA/EIA-568-B including applicable TSB's and amendments. The appropriate level IV tester shall be used to verify Category 6 cabling systems.
- F. Printouts generated for each cable by the wire (or fiber) test instrument can be submitted as part of the documentation package. The telecommunications contractor shall furnish this information in electronic form (compact disc). These discs shall contain the electronic equivalent of the test results as defined by the bid specification and be of a format readable from Microsoft Word or Microsoft Excel.
- G. When repairs and re-tests are performed, the problem found and corrective action taken shall be noted, and both the failed and passed test data shall be documented.

The **As-Built** drawings shall include cable routes and outlet locations. Their sequential number as defined elsewhere in this document shall identify outlet locations. Numbering, icons, and drawing conventions used shall be consistent throughout all documentation provided. The Owner will provide floor plans in paper and electronic (DWG, AutoCAD) formats on which as-built construction information can be added when available. These documents shall be modified accordingly by the telecommunications contractor to denote as-built information as defined above and returned to the Owner. Numbering, icons, pathways and other drawing conventions are to be assigned their own individual AutoCAD layer.