

## 270528-TC

### Hangers and Support for Telecommunications Systems

#### Part 1 - General

##### 1.1 Work Included

- A. Provide all labor, materials, tools and equipment required for the complete installation of work called for in the Construction Documents

##### 1.2 Scope of Work

This document describes the products and execution requirements relating to Communication cabling support.

- A. This section includes minimum requirements for the following:
  - J-Hooks (**Not allowed without an approved variance**)
  - Threaded Rod, Covers, Cable Trays
  - Stackable Cable Rack Spacers
- B. All cables and related terminations, support and grounding hardware shall be furnished, installed, wired, tested, labeled, and documented by the telecommunications contractor as detailed in this document.
- C. Product specifications, general design considerations, and installation guidelines are provided in this document. If the bid documents are in conflict, this specification shall take precedence. The successful vendor shall meet or exceed all requirements for the cable system described in this document providing approved products within S9.

### 1.3 Regulatory References

- A. The following industry standards are the basis for the structured cabling system described in this document.
1. **TIA/EIA**  
TIA/EIA-568-B Commercial Building Telecommunications Cabling Standard  
TIA/EIA-569-A Commercial Building Standard for Telecom Pathways and Spaces  
TIA/EIA-606 Administration Standard for the Telecommunications Infrastructure of Commercial Buildings  
TIA/EIA-607 Commercial Building Grounding/Bonding Requirements
- NFPA**  
NFPA-70 National Electric Code (NEC)-1999 ISO/IEC ISO/IEC 11801 Generic Cabling for Customer Premises
- B. The most recent versions of all documents shall apply to this project. If there is a conflict between applicable documents, the order above shall dictate the order of precedence in resolving the issue unless an enforceable local or national code is in effect.

## Part 2 - Products

### 2.1 Threaded Rod Cover

The Threaded Rod Cover shall be utilized to protect communication cable from abrasion caused by contact with threaded rod. The Threaded Rod Cover shall be manufactured from a gray flame-retardant polyethylene material that is UL94V-0 rated. The material shall be pliable to allow for easy installation.

Part Number	For Threaded Rod Size	Length
	1/2" to 5/8"	18"

- A. **J-MOD™ Cable Support System (J Hooks) J-hooks are not allowed without a variance**

Open top cable supports shall be utilized as a pathway for communication cabling. The J Hook cable supports shall be manufactured from a non-conductive material suitable for use in air-handling spaces. The cable support must maintain complete horizontal and vertical 1" bend radius control and must manage up to 50 four-pair UTP cables. The system must allow for the ability to add future cable routing capacity. The cable support must provide the ability to retain the cable bundle with Hook & Loop Cable Ties.

<b>Part Number</b>	<b>Description</b>	<b>Material*</b>	<b>Maximum Static Load (Lbs.)</b>
	J Hook for wall mount applications	Nylon	30
	J Hook for use with brackets	Nylon	30
	Chaining Bracket	Galvanized Steel	120
	Ceiling Mount Bracket – 1 level	Galvanized Steel	180
	Ceiling Mount Bracket – 3 level	Galvanized Steel	180
	Drop Wire Bracket – 1 level	Galvanized Steel	20
	Drop Wire Bracket – 3 level	Galvanized Steel	40
	Threaded Rod Bracket – 1 level	Galvanized Steel	180
	Threaded Rod Bracket – 3 level	Galvanized Steel	180
	Screw-on Beam Clamp Bracket – 1 level	Galvanized Steel	180
	Screw-on Beam Clamp Bracket – 3 level	Galvanized Steel	180

\*\* Not for use with chaining brackets

‡ Available in natural and black

\* Suitable for use in air handling spaces per UL 2043. Listed in accordance with CAN/ULC S102.2 when mounted as single units or in pairs. Minimum spacing of 4 ft. (1220mm) required between mount points. (Flame Spread Rating = 0, Smoke Developed Classification = 30)

S7 270528-TC Hangers and Support-3

**2.2 J Hook Cable Support System J-hooks are not allowed without a variance**

Open top cable supports shall be utilized as a pathway for communication cabling. The J Hook cable supports shall be manufactured from a non-conductive material suitable for use in air-handling spaces. The pre-riveted J Hook assemblies must maintain complete horizontal and vertical 1" bend radius control and must manage up to 48 four-pair UTP cables. The cable support must provide the ability to retain the cable bundle with Hook & Loop Cable Ties.

Part Number	Description	Material*	Max. Static Load (Lbs.)
	J Hook for wall mount applications only. One 1/4" (M6) mounting hole for user supplied screw.	Nylon	30
	J Hook with ceiling mount bracket that has one 3/16" (M5), 1/4" (M6), and 3/8" (M10) mounting hole.	Nylon J Hook with metal attachments	30
	J Hook with clip for use with #12 wire, threaded rod up to 3/8" in diameter, or 1/8" - 3/8" thick flanges.	Nylon J Hook with metal attachments	10
	J Hook with screw-on beam clamp for use with flanges up to 1/2" thick.	Nylon J Hook with metal attachments	30
	J Hook with screw-on beam clamp for use with flanges up to 1/2" thick. Rotates 360 degrees.	Nylon J Hook with metal attachments	30
	J Hook with hammer-on beam clamp for use	Nylon J Hook with	30

	with flanges 1/8" – 1/4" thick. Rotates 360 degrees.	metal attachments	
	J Hook with hammer-on beam clamp for use with flanges 5/16" – 1/2" thick. Rotates 360 degrees.	Nylon J Hook with metal attachments	30
	J Hook with hammer-on beam clamp for use with flanges 9/16" – 3/4" thick. Rotates 360 degrees.	Nylon J Hook with metal attachments	30
	J Hook with z-purlin clip for use with angled flanges up to 1/4" thick.	Nylon J Hook with metal attachments	30
	J Hook with c-purlin clip for use with vertical flanges up to 1/4" thick.	Nylon J Hook with metal attachments	30
	J Hook with under floor pedestal support clamp for use with pedestal support up to 1" in diameter.	Nylon J Hook with metal attachments	30

\* Suitable for use in air handling spaces per UL 2043. Listed in accordance with CAN/ULC S102.2 when mounted as single units or in pairs. Minimum spacing of 4 ft. (1220mm) required between mount points. (Flame Spread Rating = 0, Smoke Developed Classification = 30)

## Part 3 - Execution

### 3.1 Horizontal Distribution Cable Installation

Cable shall be installed in accordance with manufacturer's recommendations and best industry practices.

A pull cord (nylon; 1/8" minimum) shall be co-installed with all cable installed in any conduit.

Cable raceways shall not be filled greater than the TIA/EIA-569-A maximum fill for the raceway type or 40%.

Cables Trays shall be bonded according to OT 270526-TC and installed to manufacture specs.

If a J-hook or trapeze system is used to support cable bundles all horizontal cables shall be supported at a maximum of 48 to 60-inch (1.2 to 1.5 meter) intervals. At no point, shall cable(s) rest on acoustic ceiling grids, ducts, sprinkler systems, electrical or panels.

Cable shall be installed above fire-sprinkler systems and shall not be attached to the system or any ancillary equipment or hardware. The cable system and support hardware shall be installed so that it does not obscure any valves, fire alarm conduit, boxes, or other control devices.

Cables shall not be attached to ceiling grid or lighting fixture wires. Where support for horizontal cable is required, the contractor shall install appropriate carriers to support the cabling independently.

Any cable damaged or exceeding recommended installation parameters during installation shall be replaced by the contractor prior to final acceptance at no cost to the Owner.